


PROFILE


GENERAL NOTES

1. THE JOINING SYSTEM FOR THE FIBERGLASS CONDUIT SHALL BE NON-ADHESIVE, NON-MECHANICAL SLIP-FIT TYPE INSTALLED IN ACCORDANCE WITH MANUFACTURER'S DIRECTIONS AND GOOD WORK PRACTICE.
2. WHENEVER FIBERGLASS CONDUIT IS CUT, SMOOTH THE ROUGH (INSIDE AND OUTSIDE) BY SANDING WITH EMORY CLOTH.
3. INSTALL ONE EXPANSION JOINT PER 38 M (125') OF CONDUIT. RUN, EXPANSION JOINTS SHALL BE CAPABLE OF LONGITUDINAL MOVEMENTS OF 75 MM (3") (MIN) FOR RUNS OF 76 M (250') OR LESS. INSTALL BOTH EXPANSION JOINTS NEAR ABUTMENTS AND INSTALL ONE ANCHOR SUPPORT NEAR MIDPOINT BETWEEN EXPANSION JOINTS (SEE NOTE 11)
4. THE MANUFACTURER WILL AT THE REQUEST OF THE CONTRACTOR, COMPLETELY ASSEMBLE AN EXPANSION JOINT AND INCORPORATE IT INTO A FULL LENGTH OF CONDUIT.
5. PRESSURE TREATED WOOD SEPARATORS SHALL BE MADE FROM "DENSE STRUCTURAL SOUTHERN PINE" OR "DENSE SELECT STRUCTURAL FIR" AND SEPARATORS SHALL BE TREATED WITH PENTACHLOROPHENOL PRESERVATIVE. SIMILARLY TREATED UTILITY CROSSARMS ARE SUITABLE PROVIDED ALL DIMENSIONS SHOWN IN DETAILS "A" AND "B" ARE MAINTAINED.
6. 200 MM (8") DIA. PIPE SLEEVES WILL BE MADE OF ALUMINUM, SCH 40 (MIN) OR NON - MAGNETIC STAINLESS STEEL, SCH 40 (MIN)
7. CONDUITS AND EXPANSION JOINTS MUST BE INSTALLED SO AS TO MAINTAIN AIRTIGHT INTEGRITY FOR PNEUMATIC LINES.
8. HANGER ASSEMBLY DESIGN AND CONDUIT SUPPORT SPACINGS WERE BASED ON A COMBINED WEIGHT/M (WEIGHT/FOOT) OF CONDUIT AND CABLE OF 16.7 KG/M (11.2 LBS/FT)
9. ALL STRUCTURAL STEEL SHALL MEET THE REQUIREMENTS OF ASTM A36/ A36M-94 UNLESS OTHERWISE NOTED. ALL STRUCTURAL STEEL PLATES, SHAPES, HANGERS AND APPURTENANCES SHALL BE HOT - DIP GALVANIZED
10. DISTRIBUTOR FOR ALUMINUM & NON - MAGNETIC STAINLESS STEEL PIPE SLEEVES JOSEPH T RYERSON & SON INC , PHILADELPHIA, PA. 215-724-0700
11. TO CONTROL CONDUIT MOVEMENTS DUE TO TEMPERATURE CHANGES AND CABLE PULLING, INSTALL ONE ANCHOR SUPPORT PER 38 M (125') OF CONDUIT. ANCHOR SUPPORTS SHALL BE DESIGNED FOR A 2669 N (600 POUND) FORCE IN EITHER DIRECTION OF CONDUIT RUN. THE ANCHOR SUPPORT SHALL USE CLAMPS, CABLE TIES, ETC TO PREVENT LONGITUDINAL MOVEMENTS OF THE CONDUIT AT THIS LOCATION AND SHALL BE APPROVED BY THE DESIGNATED GPU ENERGY REPRESENTATIVE (SEE ANCHOR DETAIL)
12. THE USE OF CAST-IN-PLACE OR DRILLED-IN ANCHORS IN THE DECK SLAB OR PRECAST BEAMS IS STRICTLY PROHIBITED BY THE NEW JERSEY DOT
13. REFER TO ANY SPECIFIC REQUIREMENTS OF THE MANUFACTURER USED, FOR INSTALLATION DETAILS




DETAIL A

NOTE  
THE END HOLE OF THE 2X2 ARRANGEMENT WILL BE THE CENTER HOLE IN THE 2X4 ARRANGEMENT HOWEVER ELIMINATE THIS HOLE FOR THE 2X3 ARRANGEMENT



DETAIL B




SECTION A - A


NOTE:  
UTILITY CROSSARMS MAY BE USED AS SEPARATORS, PROVIDED SEPARATION DISTANCES ARE MAINTAINED, SEE NOTE 5  
DETAIL "A" CAN BE MADE BY USING TWO 89 X 114 MM (3 1/2" X 4 1/2") CROSSARMS MOUNTED BACK TO BACK  
DETAIL "B" CAN BE MADE BY USING A SINGLE 89 X 114 MM (3 1/2" X 4 1/2") CROSSARM  
CONDUIT BEVELS CAN THEN BE CUT TO MAINTAIN DESIRED SEPARATIONS

NOTE:  
MANUFACTURED CONDUIT SUPPORT SYSTEMS MAY BE SUBSTITUTED FOR THE PRESSURE TREATED WOOD SYSTEM SHOWN. THESE ARE AVAILABLE FROM:  
CONDUX INTERNATIONAL - BOX 247  
- MANKATO, MINNESOTA 56001  
- 800-533-2077  
GEORGE-INGRAHAM CORP - PO BOX 1869  
- STONE MOUNTAIN, GEORGIA  
- 30086-1869  
- 800-631-6283  
- FAX 404-296-0952

METRA INDUSTRIAL CORP - METRA INDUSTRIAL CORP  
P O BOX 30845  
COLUMBUS, OHIO 43230  
800-872-3828  
FAX 614-475-7759



DETAIL C



SECTION B - B

END BELL

(AT MANHOLE LOCATION)  
(SEE NOTE 13)

ANCHOR SUPPORT DETAIL

(SEE NOTE 12)

BILL OF MATERIALS

ITEM NO	DESCRIPTION	QUANTITY OF ITEMS NEEDED FOR			
		2 conduits	4 conduits	6 conduits	8 conduits
1	150 MM (6") AIRTIGHT EXPANSION JOINTS	AS REQUIRED SEE NOTES 3, 4, & 13			
2	150 MM (6") DIA. FIBERGLASS CONDUIT	NOMINAL 3 M (10') LENGTHS			
3	STAINLESS STEEL OR ALUMINUM PIPE SLEEVES	4	8	12	16
4	FLANGE END BELL, PLASTIC	AS REQUIRED			
5	CONDUIT SUPPORT SYSTEMS	AS REQUIRED			
6	EPOXY CEMENT	AS REQUIRED			

THIS SHEET FOR DESIGN INFORMATION ONLY. NOT TO BE INCLUDED IN CONTRACT PLANS.

PLATE 2.7-4

FIBERGLASS CONDUIT MANUFACTURERS (AS OF 2 - 97)

CHAMPION FIBERGLASS, INC  
P O BOX 699  
SPRING, TEXAS 77383-0699  
713-353-5052

CONTRACTORS TO VERIFY WITH SHOP DRAWINGS THAT ALL CONDUITS HAVE THE FOLLOWING MINIMUM PROPERTIES:

PIPE ID = 162.05 MM (6.380") IPS-TYPE HW  
WALL THICKNESS = 2.3 mm (0.09")  
TENSILE STRENGTH = 62 MPA (9.0) KSI  
IMPACT RESISTANCE = 190 NM @ 21°C (140 FT-LBS AT 70°F)  
TEMPERATURE RATING OF CONDUIT  
50°C OPERATING  
100°C EMERGENCY  
STIFFNESS = 345 KPA (50 LBF/IN2)  
HEAT DISTORTION = PER ASTM-D648

SUPERCEDED BY:		WORK ORDER NO:	
4	7-13-92	UPDATE TO NEW SPEC	JD JH
3	3-3-97	REVISED NOTE 8	AMD JH
2	8/86	REDRAWN	MS DB
1	10/82	CHANGED MANUFACTURER REP.	WW KK
NO	DATE	REVISION	BY CK AUT
Reading, PA			
DISTRIBUTION STANDARD			
STANDARD INSTALLATION OF 150 MM (6") FIBERGLASS CONDUIT UNDER HIGHWAY BRIDGES			
DRAWN BY:	DATE:	SCALE:	NONE
GFG	12/22/75		
CHECKED BY:	DATE:	J. L. KANE, JR.	SHT 1 OF 1
APPROVED BY:	DATE:	J. M. HOLMES	DRAWING NO.
		SIGNATURE	D-68289